

**Electric Power Industry Quality Inspection & Test Center
Of Electric Power Equipment and Instruments**

Test Report Amendment

Test Report No.: G2012142E, Dated: 11-Dec-2012

Amendment No.: – 1, Dated: 19-Feb-2013

Product: 765KV Quadruple Tension Insulator String – U210/170

Manufacturer: Insulator: Shandong Ruitai Glass Insulator Co., Ltd., China
Hardware Fittings: M/s IAC Electricals, Kolkata, India

Ratifier: Cai Qingyou, Director

Tested By: i) Yu Jiahuan, Engineer, ii) Zhang Xuejun, Engineer

Reported By: Yu Jiahuan, Engineer

Approved By: Li Qingfeng, Vice Director

Witnessed By: Ms. Sumana Mukherjee, PGCIL, India
Mr. Shen Aiqiang, Shandong Ruitai, China
Mr. Kemparaju, IAC Electricals, Kolkata, India

THE AMENDMENT TO THE REPORTS ARE AS FOLLOWS.

Clause No. 2.9: Vibration Test

Page No.: 10, Clause No.: 2.9, Line No. 7: “The six sub-conductors shall be vertically vibrated...”
must be read as “The Four Sub-Conductors shall be vertically vibrated....”

Clause No. 3.9: Page # 20, “Table – 14: The Results of Impulse Over Voltage Puncture Withstand Test”: ‘Test Results’ must please be read as below.

Test Results	<p>Test waveforms were observed and the wave amplitude and the wave front time were recorded in each impulse. Voltage gradient of each impulse was greater than 2500kV/μS. No puncture on any insulator was found during Impulse Over voltage Puncture Withstand test.</p> <p>Further, all the three power frequency flashover values on all the insulators after the Impulse Over voltage Puncture Withstand test were greater than 80 % of specified power frequency voltage flashover value of the insulator and arithmetic mean of these three power frequency flashover value of all the insulators was not less than 95 % of specified power frequency voltage flashover value of the insulator.</p>
--------------	---

All the other data in the original test report # G2012142E remain same and valid.

Ratifier (Name & Designation): Cai Qingyou, Director:


