

KEMA TEST REPORT

5113-16


<b>Object</b>	400 kV double tension insulator set 400 kV - 40 kA - 50 Hz
<b>Client</b>	Unitech Power Transmission Ltd., 3rd Floor, Unitech House, L-Block South City-I, Gurgaon-122001 (Haryana), India
<b>Manufacturers</b>	Insulator units: AO "YuAIZ" Yuzhnouralsky Insulators and Fittings Plant, 1 Zavodskaya st., Yuzhnouralsk, Chelyabinsk Region, 457040 Russian Federation <sup>*)</sup>  Fittings: IAC Electricals Pvt. Ltd., 701, Central Plaza, 2/6, Sarat Bose Road, Kolkata-700 020, India <sup>*)</sup>
<b>Tested by</b>	KEMA Laboratories Prague, Zkušebnictví, a.s., Podnikatelská 547, Prague 9, the Czech Republic
<b>Date of tests</b>	12 August 2016
<b>Test specification</b>	The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on PGCIL Specification – SECTION-IX (VOLUME-II), section No. 1.6 and based on IEC 61467:2008.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

<sup>\*)</sup> as declared by the manufacturer

This report consists of 59 pages in total.

Zkušebnictví, a.s.



Robert Jech  
Operational Manager



Laboratories

Prague, 09 September 2016